

EC-TYPE EXAMINATION CERTIFICATE (MODULE B)

Certificate no.:
MEDB00006W3
Revision no.:
2

Application of: Directive 2014/90/EU of 23 July 2014 on marine equipment (MED), issued as "Forskrift om Skipsutstyr" by the Norwegian Maritime Authority. This Certificate is issued by DNV AS under the authority of the Government of Norway.

This is to certify:

that the **Penetrations through 'A' class divisions: - electric cable transits**

with type designation(s)

Marine Flex System (180) Cable

issued to

FireSeal AB

Kista, Sweden

is found to comply with the Implementing Regulation **(EU) 2025/1533** for

Item no. **MED/3.26a** (Row 1 of 1)

according to the following requirements:


SOLAS 74 Reg. II-2/9, IMO Res. MSC.1/Circ. 1655

Further details of the equipment and conditions for certification are given overleaf.

Date of issue: **2025-10-14**

Expiry date: **2030-10-13**

DNV local unit:
Sweden CMC



for DNV AS

Approval Engineer:
Marcin Tobiasz

Notified Body
no.: **0575**

Christine Mydlak-Röder
Head of Notified Body

A U.S. Coast Guard approval number will be assigned to the equipment when the production module has been completed and will appear on the production module certificate (module D, E or F), as allowed by the Agreement between the United States of America and the EEA EFTA states on the mutual recognition of Certificates of Conformity for Marine Equipment signed 17 October 2005, and amended by Decision No 1/2023 dated August 21st, 2023.

The mark of conformity may only be affixed to the above type approved equipment and a Manufacturer's Declaration of Conformity issued when the production-surveillance module (D, E or F) of Annex B of the MED is fully complied with and controlled by a written inspection agreement with a Notified Body. The product liability rests with the manufacturer or his representative in accordance with Directive 2014/90/EU.

This certificate is valid for equipment, which is conform to the approved type. The manufacturer shall inform DNV AS of any changes to the approved equipment. This certificate remains valid unless suspended, withdrawn, recalled or cancelled.

Should the specified regulations or standards be amended during the validity of this certificate, the product is to be re-approved before being placed on board a vessel to which the amended regulations or standards apply.

LEGAL DISCLAIMER: Unless otherwise stated in the applicable contract with the holder of this document, or following from mandatory law, the liability of DNV AS, its parent companies and their subsidiaries as well as their officers, directors and employees ("DNV") arising from or in connection with the services rendered for the purpose of the issuance of this document or reliance thereon, whether in contract or in tort (including negligence), shall be limited to direct losses and under any circumstance be limited to USD 300 000.



Product description

"Marine Flex System (180) Cable"

Consisting of a min. 180 mm long steel sleeve, circular or rectangular, welded to the steel bulkhead/deck with "Marine Blanket" (nominal density of 96 kg/m³) packed into the cavity between sleeve and cables. The sleeve is sealed at both ends with a layer of min. 15 mm thick "Marine Flex".

The rectangular steel sleeve may incorporate a 330 mm long intumescent sleeve with 50 mm diameter, either cable filled or empty. If installed empty, both ends of the intumescent sleeve shall be capped with supplied lids or with min. 7 mm thick "Marine Flex" sealant on one side. If cable filled, the end of the intumescent sleeve shall be sealed with min. 7 mm thick "Marine Flex" sealant on one side.

For further details, see drawing under Type Examination documentation below.

Application/Limitation

Approved for use as cable penetration system in class A-0 steel bulkheads/decks as specified in the Appendix. Other applications are subject to case-by-case approval.

Each product is to be supplied with its manual for installation and maintenance.

Please see Appendix: Application/Limitation

Type Examination documentation

Tests carried out

Tested according to IMO 2010 FTP Code part 3.

Marking of product

The product or packing is to be marked with name and address of manufacturer, type designation, fire technical rating, MED Mark of Conformity and USCG approval number if applicable (see first page).

APPENDIX

Application/Limitation

Certificate no.:
MEDB00006W3
Revision no.:
2

Table 1: Approved cable penetration in A-0 steel bulkhead.

Type	Size (H x W) [mm]	Max. cable diameter (OD) [mm]	Filling ratio ¹⁾ [%]	Sleeve length [mm]	Sleeve thickness [mm]	Sleeve position	Sleeve insulation
Circular	Ø48 – Ø250	85	0 – 40	180	3.0	Symmetric	Uninsulated
Circular	Ø35 – Ø300	77	0 – 41	200	3.0	Symmetric	Uninsulated
Rectangular	100x100 – 700x300	85	0 – 40	180	3.0 – 4.5	Symmetric	Uninsulated
Rectangular	100x50 – 800x400	77 ²⁾	0 – 40	200	3.0	Symmetric	Uninsulated

1) Min. distance between cables/bundle and between cables/bundle and sleeve is 5 mm.

2) Max. size of cable OD.35mm inside 330 mm long intumescent sleeve with diameter 50 mm.

Table 2: Approved cable penetration in A-0 steel deck.

Type	Size (H x W) [mm]	Max. cable diameter (OD) [mm]	Filling ratio ¹⁾ [%]	Sleeve length [mm]	Sleeve thickness [mm]	Sleeve position	Sleeve insulation
Circular	Ø48 – Ø250	85	0 – 40	180	3.0	Symmetric	Uninsulated
Circular	Ø35 – Ø300	77	0 – 41	200	3.0	Symmetric	Uninsulated
Rectangular	100x100 – 700x300	85	0 – 40	180	3.0 – 4.5	Symmetric	Uninsulated
Rectangular	100x50 – 800x400	77 ²⁾	0 – 40	200	3.0	Symmetric	Uninsulated

1) Min. distance between cables/bundle and between cables/bundle and sleeve is 5 mm.

2) Max. size of cable OD.35mm inside 330 mm long intumescent sleeve with diameter 50 mm.



APPENDIX

Other

Certificate no.:
MEDB00006W3
Revision no.:
2

Product description

"Marine Flex System (180) Cable"

Consisting of a min. 180 mm long steel sleeve, circular or rectangular, welded to the steel bulkhead/deck with "Marine Blanket" (nominal density of 96 kg/m³) packed into the cavity between sleeve and cables. The sleeve is sealed at both ends with a layer of min. 15 mm thick "Marine Flex".

Application/Limitation

Circular penetration:

Approved for penetration in steel bulkheads or decks limited to a pressure of 2 bar (tested pressure 3 bar) watertightness and 0.033 bar (tested pressure 0.05 bar) gastightness (smoke tight) for approved ship cables.

Rectangular penetration:

Approved for penetration in steel bulkheads or decks limited to a pressure of 1.33 bar (tested pressure 2.0 bar) watertightness and 0.033 bar (tested pressure 0.05 bar) gastightness (smoke tight) for approved ship cables.

The penetration system is not to be used for penetrating boundaries of tanks.

Type Approval documentation

Pressure test report No. FS-RP2104-03 dated 13 April 2021 from FireSeal, Kista, Sweden.

Pressure test report No. FS-RP2104-04 dated 13 April 2021 from FireSeal, Kista, Sweden.

Pressure test report No. FS-RP2104-05 dated 13 April 2021 from FireSeal, Kista, Sweden.

Pressure test report No. FS-RP2104-06 dated 13 April 2021 from FireSeal, Kista, Sweden.

Pressure test report No. FS-RP2104-07 dated 13 April 2021 from FireSeal, Kista, Sweden.

Pressure test report No. FS-RP2104-08 dated 13 April 2021 from FireSeal, Kista, Sweden.

Pressure test report No. FS-RP2504-07 dated 28 April 2025 from FireSeal, Kista, Sweden.

Tests carried out

Pressure tests according to DNV-CP-0165, September 2021.